

**LONGITUDINAL DENSITY MODULATION OF UNSTABLE BUNCHES  
EMITTING COHERENT IR**

B. Podobedov, G.L. Carr, S.L. Kramer and J.B. Murphy  
National Synchrotron Light Source  
Brookhaven National Laboratory  
P.O. Box 5000  
Upton, NY, USA 11973-5000

June 2001

**National Synchrotron Light Source**

Brookhaven National Laboratory  
Operated by  
Brookhaven Science Associates  
Upton, NY 11973

Under Contract with the United States Department of Energy  
Contract Number DE-AC02-98CH10886

## DISCLAIMER

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

# BNL ACCELERATOR TEST FACILITY CONTROL SYSTEM UPGRADE

R. Malone, I. Ben-Zvi, X. Wang, V. Yakimenko  
BNL<sup>†</sup>, Upton, NY 11973, USA

## Abstract

Brookhaven National Laboratory's Accelerator Test Facility (ATF) has embarked on a complete upgrade of its decade old computer system. The planned improvements affect every major component: processors (Intel Pentium replaces VAXes), operating system (Linux/Real-Time Linux supplants OpenVMS), and data acquisition equipment (fast Ethernet equipment replaces CAMAC serial highway.) This paper summarizes the strategies and progress of the upgrade along with plans for future expansion.

## 1 INTRODUCTION

Commissioned in 1990, ATF was formed to carry out long-term research in accelerator physics including new concepts, devices and technologies to improve future linear colliders and light sources. As a dedicated user facility, around 1100 hours per year of beam time are made available to researchers from government laboratories, universities and industry to perform committee-approved experiments at the facility's three beam lines. ATF's core capabilities include a high brightness photoinjector electron gun, a 70 MeV electron accelerator and a fully instrumented experiment hall. Facility operators and users have access to essentially all of this equipment through the main control system.

## 2 OVERVIEW OF PRESENT SYSTEM

The ATF control system hardware (shown schematically in Fig. 1) was originally configured and installed in 1990 [1] and has remained essentially unchanged since that time.

Centered around a 114 MHz VAX 4200 (single CPU) equipped with 56 Mb of main memory, 1.7 Gb of disk storage and 10 MHz Ethernet interface, the Q-bus based VAX has provided control system and data acquisition services continuously for over a decade. Data acquisition is CAMAC-based, driven by a Kinetic Systems Corporation model 2160 serial highway driver [2] with six crates positioned at various locations around the facility. Each is equipped with a type L2 enhanced serial crate controller, communicating over a 5 MHz metallic serial highway cable, which is daisy-chained between the crates.

The software consists of Compaq (originally Digital)'s Open VMS operating system [3] together with TGV's Multinet TCP/IP stack. Compaq compilers were used to

develop application programs in C and Fortran. All operator displays and supporting databases were built using Vsystem, a commercial software tool package from Vista Control Systems, Inc. [4]




Figure 1: Schematic of present ATF control system.

Although the top-level functionality of the control system is highly sophisticated and readily applicable to the required tasks, the limitations of decade-old hardware are apparent. The primary problem is the speed of the system: activation of new processes is slow, bordering on the very edge of acceptability. The number of applications programs and services developed since commissioning has increased to the point where the severe limitation of computing resources makes it impossible to add new advanced capabilities such as extended on-line modeling and global feedback algorithms. The support of legacy hardware and software is also an issue for concern. The need to improve the system has been apparent since 1995, but limited funding precluded any upgrade until recently.

## 3 UPGRADE PHILOSOPHY AND KEY DECISIONS

Early in the discussions of how best to improve the control system, a clear consensus on general strategies emerged:

- Use off-the-shelf, commodity hardware and software wherever possible.
- Invest in those technologies with clear expansion and upgrade pathways and which improve ATF's overall flexibility, stability and reliability.

<sup>†</sup>Supported by the U.S. Department of Energy under contract DE-AC02-98CH10886

- Preserve investments made in data acquisition and control hardware while allowing for new hardware families to be introduced (VME, VXI.)
- Maintain the current level of familiarity users have with the present system by porting applications software and operator displays, hopefully making the behind-the-scenes upgrades transparent. Any plan that would require major retraining of personnel was deprecated.

But the most important (and challenging) requirement:

- Minimize disruption to the on-going scientific program. All upgrade work must occur while still maintaining the present control system at full operational readiness. Final cutover to the new system should entail as little disturbance to operations as practicable.

Based on these guidelines, key decisions were reached:

- Move from VAX hardware to the ubiquitous Intel Pentium-based machines (see specifications below.)
- Replace L2-serial crate controllers with 100 MHz Ethernet crate controllers, fed through a fast Ethernet switch driven from the new host.
- Remove the serial highway, replacing it with a private fast Ethernet sub-network.
- Use Linux instead of VMS, employing real-time Linux (RT-Linux [5]) for hard real-time tasks. (Windows NT was not found to be sufficiently stable in meeting ATF requirements during preliminary evaluations.)
- Replace operator workstations (previously X-Window terminals) with Windows NT PCs. This allows X-displays to operate side-by-side with “shrink-wrapped” applications like Mathcad, Matlab and LabView.
- Maintain external networked services as is, instead rewriting only the network socket listener which supports such services. (This includes video frame grabbers, Mathcad interfaced via network, visual C++ applications and LabView programs.)
- Continue with the successful use of Vsystem development tools

The machine chosen to be the new control system host is an IBM Netfinity 8500R server [6]. Initially, it will operate with two 700 MHz Pentium-III Xeon processors (expandable to eight CPUs), 1.5Gb main memory (expandable to 64 Gb), 17Gb RAID disk storage and 40Gb SCSI DLT tape drive. Three network interface cards permit external communications: one strictly for data acquisition, the second for data communication within ATF and the third for general network access. The machine is also equipped with three redundant, hot-swap power supplies, fed from an uninterruptible power supply

with sufficient capacity to operate for around 30 minutes in the event of AC power loss. The new host and data acquisition is shown schematically in Figure 2.




Figure 2: Schematic of new ATF control system

## 4 THE SYSTEM IN TRANSITION

### 4.1 Parallel operation of data acquisition hardware

During the upgrade process, each CAMAC crate will continue to operate with its L2 controller acting as a primary controller with the new Ethernet crate controllers introduced as auxiliary controllers. This will permit shared access to the CAMAC hardware for both the old and new control systems. This allows testing of the new system with actual loads during maintenance periods, nights and weekends and other times when regular beam operation is not required. It also hastens porting of existing software and provides a degree of quality control since anomalous behavior of new applications can be understood by rapid and direct comparison to a known working system. When all upgrade and porting tasks have been completed, the serial controllers and the serial highway will be removed and the Ethernet controllers reconfigured for primary controller operation. At that point, the VAX will be removed from service and the entire operation will be through the new IBM host.

### 4.2 Graphic User Interface

One of the important features of the control system is its graphical user interface, comprised of around 800 displays that present various views of the accelerator, from high-level overviews of entire beam lines, down to individual devices. (Figure 3 shows a sample screen dump from an operator terminal.) Facility operators and visiting users have come to appreciate the user-friendliness inherent in the displays and have built up significant institutional knowledge of “where to find things” using them. To maintain the same level of user productivity, it is critical therefore to maintain the same look and feel of

the present control system once it is fully operational on the new hardware.




Figure 3: Sample Operator Display

It would be far too difficult (and error prone) to manually reconstruct all of the displays of the existing system. To automate the conversion process, a two-pass approach is used. First, using a Vsystem conversion utility, the static drawing elements (lines, geometric figures, text headings, etc.) are translated from the VMS metafile format to that needed under Linux.

At this point, the displays appear to be correct, but still have internal problems, mostly related to VMS filename syntax and upper/lower case issues. In the second step, a perl script analyzes the file references in each drawing, converting them to appropriate Linux filenames. A generalization of the perl script also analyzes the entire set of displays, looking for references to non-existent displays or possible orphans (displays not referenced by any other.) Such tools are vital in ensuring the proper operation of the conversion process and can be also be reused in the future as new displays are created and added to the active system.

#### 4.3 Applications program porting

Another area of significant effort is in porting applications programs. Some 75,000 lines of code have been generated over the past 10 years, most all of it needed for daily operations. Originally written in C and Fortran, these applications are being rewritten in C++. This presents the largest challenge to the entire upgrade task and is its most labor-intensive. Development tools from the Portland Group, Inc. will be used since they can exploit the multiple processors of the new system and also handle VAX compiler language extensions. Again, perl scripts will be used in the conversion process by

generating templates for new source code which is then manually edited to translate from the original.

## 5 PROGRESS AND PLANS

To date, the new IBM server has been delivered, Linux installed and configured. The private section of fast Ethernet has been extended to all areas of the facility requiring data acquisition and the switch installed. Fiber optic cable has also been installed at all key locations in preparation for future expansion. All of the operator displays have been converted to Linux file format and the supporting databases have been tested. The CAMAC equipment has been configured for dual-controller operations and will be exercised heavily during Summer 2001. Work continues porting applications programs and will continue into Winter 2002, hopefully when the present system will be retired and the new one will assume full operational status.

Future plans call for new hardware families (VME, VXI) to be introduced to provide a wider spectrum of data acquisition hardware beyond the limited offerings of CAMAC.

With additional processing power available, more extensive on-line modeling will be initiated as well as development and implementation of new feedback and control algorithms.

## 6 CONCLUSIONS

Brookhaven's Accelerator Test Facility is undertaking an aggressive campaign to upgrade its computer control system. A careful, cost-effective plan is being executed which will enhance the facility's capabilities and provide better service to the accelerator physics community. Users can look forward to significantly improved performance, without the need for retraining. Work on the conversion effort is expected to be concluded around Winter 2002.

## 7 REFERENCES

- [1] R. Malone, I. Bottke, R. Fernow, and I. Ben-Zvi, "The BNL Accelerator Test Facility Control System", Proceedings of the Eighth IEEE Real-time Conference, Vancouver, B.C., June 8-11, 1993 (TRIUMF report TRI-93-1)
- [2] Kinetic Systems Corporation, 900 North State Street, Lockport, IL 60441
- [3] Compaq Computer Corporation, PO Box 69200, Houston, TX 77269
- [4] Vista Control Systems, 176 Central Park Square, Los Alamos, NM 87544
- [5] FSM Labs, PO Box 1822, Socorro, NM 87801
- [6] IBM Corporation, New Orchard Road, Armonk, NY 10504